



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/10/2017
Received: 10/6/17 13:56
Temp. on Receipt: 15.4 °C
Sampled By: A. Tuckey
Work Order: 7279026

C Oceanside Water District
L Attn: Alan Tuckey
I PO Box 360
E Oceanside OR, 97134-0360
N Phone: (503) 842-6462
T

Project # : N/A

PWSID # : 4100585

Sampling Location: Cape Meares Com. Ctr

Lab Number

7279026-01 **Sampled At:** Outside Spigot **Sample Matrix:** Drinking Water **Sampled:** 10/6/17 10:05
Address: Cape Meares Com. Ctr **Res. Cl:** 0.68 mg/L
Sample Type: Routine

	Method	Result	Analysis Begun / Ended	
Microbiological Analysis				
A Total Coliforms	SM 9223B (colilert-18) 21st Ed.	Absent	10/6/17 15:52	10/7/17 11:28
A E. coli	SM 9223B (colilert-18) 21st Ed.	Absent	10/6/17 15:52	10/7/17 11:28

Send results to DHS-DWP P.O. Box 14350, Portland, OR 97293-0350

A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by:
Vandana Gadi
Microbiology Technical Director



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/10/2017
Received: 10/6/17 13:56
Temp. on Receipt: 15.4 °C
Sampled By: A. Tuckey
Work Order: 7279025

C **Oceanside Water District**
L Attn: Alan Tuckey
I PO Box 360
E Oceanside OR, 97134-0360
N Phone: (503) 842-6462
T

Project # : N/A

PWSID # : 4100585

Sampling Location: Oceanside Wayside Park

Lab Number

7279025-01 **Sampled At:** Men's Bathroom Sink **Sample Matrix:** Drinking Water **Sampled:** 10/6/17 8:38
Address: Oceanside Wayside Park **Res. Cl:** 0.84 mg/L
Sample Type: Routine

	Method	Units	Result	MRL	Date/ Time Analysis Begun
Microbiological Analysis					
A	Total Coliforms	SM 9223B (colilert-18) 21st Ed.	MPN/100 mL	<1	1 10/06/17 16:10
A	E. coli	SM 9223B (colilert-18) 21st Ed.	MPN/100 mL	<1	1 10/06/17 16:10

Analyzed: 10/07/17 11:28

Analyzed by: VG

MRL = Minimum Reporting Limit

A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: _____

Vandana Gadi
Microbiology Technical Director



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

Reported: 10/10/2017
Received: 10/6/17 13:56
Temp. on Receipt: 15.4 °C
Sampled By: A. Tuckey
Work Order: 7279023

C Oceanside Water District
L Attn: Alan Tuckey
I PO Box 360
E Oceanside OR, 97134-0360
N Phone: (503) 842-6462
T

Project # : N/A

PWSID # : 4100585

Sampling Location: Cape Mears WTP

Lab Number

7279023-01 **Sampled At:** Raw Tap **Sample Matrix:** Water **Sampled:** 10/6/17 9:51
Address: Cape Mears WTP
Sample Type: LT2

	Method	Units	Result	MRL	Date/ Time Analysis Begun
Microbiological Analysis					
A <i>E. coli</i>	SM 9223B (colilert-18) 21st Ed.	MPN/100 mL	2	1	10/06/17 16:10
Analyzed: 10/07/17 11:28					Analyzed by: VG

MRL = Minimum Reporting Limit

A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by:
Vandana Gadi
Microbiology Technical Director



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/10/2017
Received: 10/6/17 13:56
Temp. on Receipt: 15.4 °C
Sampled By: A. Tuckey
Work Order: 7279022

C Oceanside Water District
L Attn: Alan Tuckey
I PO Box 360
E Oceanside OR, 97134-0360
N Phone: (503) 842-6462
T

Project # : N/A

PWSID # : 4100585

Sampling Location: WTP (Oceanside)

Lab Number

7279022-01 **Sampled At:** Raw Sample Tap **Sample Matrix:** Water **Sampled:** 10/6/17 9:00
Address: WTP (Oceanside)
Sample Type: LT2

	Method	Units	Result	MRL	Date/ Time Analysis Begun
Microbiological Analysis					
A <i>E. coli</i>	SM 9223B (collert-18) 21st Ed.	MPN/100 mL	145	1	10/06/17 16:10

Analyzed: 10/07/17 11:28

Analyzed by: VG

MRL = Minimum Reporting Limit

A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: Vandya Gadi
Vandya Gadi
Microbiology Technical Director