



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 12/12/2017  
Received: 12/04/2017  
Sampled By: Customers  
Work Order: 7338005

**C** Oceanside Water District  
**L** Attn: Alan Tuckey  
**I** PO Box 360  
**E** Oceanside OR, 97134-0360  
**N** Phone: (503) 842-6462  
**T**

**Project:**  
Project # : N/A  
PWSID # : 4100585

Sampling Location: Various Addresses/Locations

**Lab Number**

Lab Number	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>7338005-01</b>	<b>Sample Name:</b> OWD - 1 <b>Sampled:</b> 11/29/17 0:00						<b>Matrix:</b> Drinking Water
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	0.127	0.050	1.3	12/08/17 13:52
A Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	12/11/17 14:28
<b>7338005-02</b>	<b>Sample Name:</b> OWD - 2 <b>Sampled:</b> 11/29/17 0:00						<b>Matrix:</b> Drinking Water
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	12/08/17 13:52
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	12/11/17 14:28
<b>7338005-03</b>	<b>Sample Name:</b> OWD - 3 <b>Sampled:</b> 11/29/17 0:00						<b>Matrix:</b> Drinking Water
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	0.121	0.050	1.3	12/08/17 13:52
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	12/11/17 14:28
<b>7338005-04</b>	<b>Sample Name:</b> OWD - 4 <b>Sampled:</b> 11/29/17 0:00						<b>Matrix:</b> Drinking Water
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	12/08/17 13:52
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	12/11/17 14:28
<b>7338005-05</b>	<b>Sample Name:</b> OWD - 5 <b>Sampled:</b> 11/29/17 0:00						<b>Matrix:</b> Drinking Water
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	ND	0.050	1.3	12/08/17 13:52
A Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	12/11/17 14:28
<b>7338005-06</b>	<b>Sample Name:</b> OWD - 6 <b>Sampled:</b> 11/30/17 0:00						<b>Matrix:</b> Drinking Water
<i>Metals (Total)</i>							
A Copper	1055	SM3111B	mg/L	0.159	0.050	1.3	12/08/17 13:52
A Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	12/11/17 14:28



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 12/12/2017  
Received: 12/04/2017  
Sampled By: Customers  
Work Order: 7338005

**C** Oceanside Water District  
**L** Attn: Alan Tuckey  
**I** PO Box 360  
**E** Oceanside OR, 97134-0360  
**N** Phone: (503) 842-6462  
**T**

**Project:**  
Project # : N/A  
PWSID # : 4100585

Sampling Location: Various Addresses/Locations

**Lab Number**

Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>7338005-07</b> Sample Name: OWD - 7 Matrix: Drinking Water Sampled: 11/30/17 0:00						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	0.070	0.050	1.3	12/08/17 13:52
A Lead	1030 EPA 200.9	mg/L	ND	0.002	0.015	12/11/17 14:28
<b>7338005-08</b> Sample Name: OWD - 8 Matrix: Drinking Water Sampled: 11/30/17 0:00						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	ND	0.050	1.3	12/08/17 13:52
A Lead	1030 EPA 200.9	mg/L	ND	0.002	0.015	12/11/17 14:28
<b>7338005-09</b> Sample Name: OWD - 9 Matrix: Drinking Water Sampled: 11/30/17 7:30						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	0.136	0.050	1.3	12/08/17 13:52
A Lead	1030 EPA 200.9	mg/L	0.005	0.002	0.015	12/11/17 14:28
<b>7338005-10</b> Sample Name: OWD - 10 Matrix: Drinking Water Sampled: 12/1/17 8:00						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	ND	0.050	1.3	12/08/17 13:52
A Lead	1030 EPA 200.9	mg/L	ND	0.002	0.015	12/11/17 14:28

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit  
**A** = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: \_\_\_\_\_

Adriana Gonzalez-Gray  
Laboratory Director